ပ ī

0

G

~

ш Z **Case Study ID** 96-0002



Study Serie

Ann Arbor City Hall

Natural Gas Powered Chiller

Description

An obsolete 200 ton, TonRack electric powered chiller in the Ann Arbor City Hall was replaced in March of 1992 with a new, 150 ton TecoChill brand gas powered chiller to provide air-conditioning for the 90,000 square foot building. The cost to install the chiller, after MichCon's incentive rebate of \$35,000 was \$156,000 (this cost includes additional work done to replace cooling coils). The installation of this new chiller reversed the trend of increasing electric costs, which was averaging a 6% increase per year. Further electric bill savings for the city hall have also been realized through additional energy saving measures, including lighting retrofits and a building energy management system installed in 1996.


Gas Chiller Features

- variable speed operation allowing load following capability
- routine maintenance conducted by in-house staff
- bi-annual servicing by a TecoChill technician at a cost of \$1,400/year
- nearly problem free operation since its installation
- The manufacturer predicted an engine rebuilt would be required after 15,000 running hours at a cost of \$8000.
- The chiller has logged over 17,900 running hours, with an average load of 46%, with no engine rebuild required to date.

Energy Savings

- Electric costs rose over 6% per fiscal year between 1987 and 1991.
- After the natural gas chiller was installed, the electric costs have decreased
- Electric costs were lower for FY95-96 than they were for FY 86-87.
- After the natural gas chiller was installed, the natural gas costs have increased every fiscal year.
- The electric cost decrease outweighs the natural gas increase, creating a net annual energy savings. The annual savings has averaged \$28,000/year since 1992 compared to the baseline costs for fiscal year 91-92.
- A portion of the electric cost decrease is due to a decrease in the electric demand cost. This decrease in cost can be attributed to the gas chiller.
- Future energy savings in the building may reflect energy conservation measures performed in 1996, including lighting system retrofits and the installation of an

Pre- and Post Chiller Installation Energy Usage



For more information regarding this Energy Project or ideas for future case studies contact:

Dave Konkle Municipal Energy Coordinator Rebuild Michigan Ann Arbor City Hall 100 N. Fifth Avenue Ann Arbor, MI 48107-8647 (313) 996-3150

Tim Shireman Michigan Energy Office P.O. Box 30221 Lansing, MI 48909 (517) 241-6228

